

**TEMPORARY/CONDITIONAL POWER APPLICATION  
CITY OF GOLDSBORO**

10 DIGIT PREMISE # \_\_\_\_\_ (REQUIRED)      DATE: \_\_\_\_\_

APPLICANT'S NAME: \_\_\_\_\_ PHONE: \_\_\_\_\_

APPLICANT'S ADDRESS: \_\_\_\_\_

PROJECT NAME: \_\_\_\_\_

ADDRESS POWER REQUESTED FOR: \_\_\_\_\_

DURATION OF TEMPORARY POWER \_\_\_\_\_ DAYS

**PORTIONS OF PERMANENT WIRING SYSTEM TO BE ENERGIZED:**

	<u>YES</u>	<u>NO</u>
HVAC WIRING	_____	_____
LIGHTING CIRCUITS	_____	_____
*120-V RECEPTACLE CIRCUITS	_____	_____
OTHER (SPECIFY) _____		

**NOTE: ALL 120-V RECEPTACLE CIRCUITS TO BE ENERGIZED MUST HAVE GFCI PROTECTION**

**THE FOLLOWING STATEMENTS REQUIRE SIGNATURES BY BOTH CONTRACTORS AND INSPECTORS**

**1. THE PORTIONS OF THE PERMANENT WIRING SYSTEM STATED ABOVE ARE SUITABLE TO BE ENERGIZED.**

ELECTRICAL CONTRACTOR'S SIGNATURE \_\_\_\_\_

ELECTRICAL PERMIT # \_\_\_\_\_

ELECTRICAL INSPECTOR'S SIGNATURE \_\_\_\_\_

**2. THE MECHANICAL EQUIPMENT IS SUITABLE TO BE ENERGIZED AND OPERATED.**

MECHANICAL CONTRACTOR'S SIGNATURE \_\_\_\_\_

MECHANICAL PERMIT # \_\_\_\_\_

MECHANICAL INSPECTOR'S SIGNATURE \_\_\_\_\_

**3. THE PLUMBING EQUIPMENT IS SUITABLE TO BE ENERGIZED AND OPERATED.**

**PLUMBING CONTRACTOR'S SIGNATURE** \_\_\_\_\_

**PLUMBING PERMIT #** \_\_\_\_\_

**PLUMBING INSPECTOR'S SIGNATURE** \_\_\_\_\_

**4. THE FIRE/LIFE SAFETY EQUIPMENT IS SUITABLE TO BE ENERGIZED AND OPERATED.**

**REQUIRED CONTRACTOR'S SIGNATURE** \_\_\_\_\_

**FIRE PERMIT #** \_\_\_\_\_

**FIRE INSPECTOR'S SIGNATURE** \_\_\_\_\_

**5. UPON RECEIVING TEMPORARY POWER \_\_\_\_\_ (BUILDING CONTRACTOR), WILL BE RESPONSIBLE TO SUPERVISE USE OF SUCH POWER AND WILL INSURE THAT ALL REQUIREMENTS TO SUPERVISE USE OF SUCH POWER AND WILL INSURE THAT ALL REQUIREMENTS OF \*SECTION 10.8 OF THE NORTH CAROLINA STATE BUILDING CODE ARE STRICTLY ADHERED TO. (\*COPY ATTACHED).**

**BY SIGNING BELOW I AGREE THAT IF THE BUILDING IS OCCUPIED PRIOR TO A CERTIFICATE OF OCCUPANCY BEING ISSUED, I WILL FORFEIT THE \$2500.00/\$500.00 TEMPORARY POWER DEPOSIT.**

**RESPONSIBLE AGENT \_\_\_\_\_ (SIGNATURE)**

**BUILDING PERMIT # \_\_\_\_\_**

**BUILDING INSPECTOR'S SIGNATURE \_\_\_\_\_**

.....  
**\*A CERTIFIED CHECK, BUSINESS CHECK, OR MONEY ORDER FOR \$2500.00 MUST BE LEFT WITH THE CITY OF GOLDSBORO WHEN REQUESTING TEMPORARY POWER FOR ANY COMMERCIAL PROPERTY.**

**\*A CERTIFIED CHECK, BUSINESS CHECK, OR MONEY ORDER FOR \$500.00 MUST BE LEFT WITH THE CITY OF GOLDSBORO WHEN REQUESTING TEMPORARY POWER FOR ANY RESIDENTIAL PROPERTY.**

**\*THE ELECTRICAL INSPECTOR SHALL CONTACT THE POWER COMPANY TO ENERGIZE THE ELECTRICAL SERVICE WHEN ALL REQUIREMENTS HAVE BEEN MET.**

## **10.8 Temporary Power**

**10.8.1 Scope.** The provisions of this section apply to the utilization of portions of the wiring system within a building to facilitate construction.

**10.8.2 Provisions for Temporary Power.** The Code enforcement official shall give permission and issue a permit to energize the electrical service when the provisions of 10.8 and the following requirements have been met:

- 1) The service wiring and equipment, including the meter socket enclosure, shall be installed, the service wiring terminated, and the service equipment covers installed.
- 2) The portions of the electrical system that are to be energized shall be complete and physically protected.
- 3) The grounding electrode system shall be complete.
- 4) The grounding and the grounded conductors shall be terminated in the service equipment.
- 5) At least one receptacle outlet with ground fault circuit interrupter protection for personnel shall be installed with the circuit wiring terminated.
- 6) The applicable requirements of the North Carolina Electrical Code apply.

**10.8.3 Uses Prohibited.** In no case shall any portion of the permanent wiring be energized until the portions have been inspected and approved by an electrical Code Enforcement Official. Failure to comply with this section may result in disconnection of power or revocation of permit.

## **10.8.4 Application for Temporary Power.**

Application for temporary power shall be made by and in the name of the applicant. The application shall explicitly state the portions of the energized electrical system, mechanical system, or plumbing system for which application is made, its intended use and duration.

**10.8.5 Security and Notification.** The applicant shall maintain the energized electrical system or that portion of the building containing the energized electrical system in a secured and locked manner or under constant supervision to exclude unauthorized personnel. The applicant shall alert personnel working in the vicinity of the energized electrical system to its presence.

## **10.9 Requirements of Other State Agencies, Occupational Licensing Boards, or Commissions**

The North Carolina State Building Codes do not include all additional requirements for buildings and structures that may be imposed by other State agencies, occupational licensing boards, and commissions. It shall be the responsibility of a permit holder, design professional, contractor, or occupational license holder to determine whether any additional requirements exist.