

**TEMPORARY/CONDITIONAL POWER APPLICATION
CITY OF GOLDSBORO**

10 DIGIT PREMISE # _____ (REQUIRED) DATE: _____

APPLICANT'S NAME: _____ PHONE: _____

APPLICANT'S ADDRESS: _____

PROJECT NAME: _____

ADDRESS POWER REQUESTED FOR: _____

DURATION OF TEMPORARY POWER _____ DAYS

PORTIONS OF PERMANENT WIRING SYSTEM TO BE ENERGIZED:

	<u>YES</u>	<u>NO</u>
HVAC WIRING	_____	_____
LIGHTING CIRCUITS	_____	_____
*120-V RECEPTACLE CIRCUITS	_____	_____
OTHER (SPECIFY) _____		

NOTE: ALL 120-V RECEPTACLE CIRCUITS TO BE ENERGIZED MUST HAVE GFCI PROTECTION

THE FOLLOWING STATEMENTS REQUIRE SIGNATURES BY BOTH CONTRACTORS AND INSPECTORS

1. THE PORTIONS OF THE PERMANENT WIRING SYSTEM STATED ABOVE ARE SUITABLE TO BE ENERGIZED.

ELECTRICAL CONTRACTOR'S SIGNATURE _____

ELECTRICAL PERMIT # _____

ELECTRICAL INSPECTOR'S SIGNATURE _____

2. THE MECHANICAL EQUIPMENT IS SUITABLE TO BE ENERGIZED AND OPERATED.

MECHANICAL CONTRACTOR'S SIGNATURE _____

MECHANICAL PERMIT # _____

MECHANICAL INSPECTOR'S SIGNATURE _____

3. THE PLUMBING EQUIPMENT IS SUITABLE TO BE ENERGIZED AND OPERATED.

PLUMBING CONTRACTOR'S SIGNATURE _____

PLUMBING PERMIT # _____

PLUMBING INSPECTOR'S SIGNATURE _____

4. THE FIRE/LIFE SAFETY EQUIPMENT IS SUITABLE TO BE ENERGIZED AND OPERATED.

REQUIRED CONTRACTOR'S SIGNATURE _____

FIRE PERMIT # _____

FIRE INSPECTOR'S SIGNATURE _____

**5. UPON RECEIVING TEMPORARY POWER _____ (BUILDING CONTRACTOR),
WILL BE RESPONSIBLE TO SUPERVISE USE OF SUCH POWER AND WILL INSURE THAT ALL REQUIREMENTS TO
SUPERVISE USE OF SUCH POWER AND WILL INSURE THAT ALL REQUIREMENTS OF *SECTION 10.8 OF THE
NORTH CAROLINA STATE BUILDING CODE ARE STRICTLY ADHERED TO. (*COPY ATTACHED).**

**BY SIGNING BELOW I AGREE THAT IF THE BUILDING IS OCCUPIED PRIOR TO A CERTIFICATE OF OCCUPANCY
BEING ISSUED, I WILL FORFEIT THE \$2500.00/\$500.00 TEMPORARY POWER DEPOSIT.**

RESPONSIBLE AGENT _____ (SIGNATURE)

BUILDING PERMIT # _____

BUILDING INSPECTOR'S SIGNATURE _____

.....
***A CERTIFIED CHECK, BUSINESS CHECK, OR MONEY ORDER FOR \$2500.00 MUST BE LEFT
WITH THE CITY OF GOLDSBORO WHEN REQUESTING TEMPORARY POWER FOR ANY
COMMERCIAL PROPERTY.**

***A CERTIFIED CHECK, BUSINESS CHECK, OR MONEY ORDER FOR \$500.00 MUST BE LEFT WITH
THE CITY OF GOLDSBORO WHEN REQUESTING TEMPORARY POWER FOR ANY RESIDENTIAL
PROPERTY.**

***THE ELECTRICAL INSPECTOR SHALL CONTACT THE POWER COMPANY TO
ENERGIZE THE ELECTRICAL SERVICE WHEN ALL REQUIREMENTS HAVE BEEN MET.**

2020 North Carolina Electrical Code

10.8 Temporary Power

10.8.1 Scope

The provisions of this section apply to the utilization of portions of the wiring system within a building to facilitate construction.

10.8.2 Provisions for Temporary Power

The Code enforcement official shall give permission and issue a permit to energize the electrical service when the provisions of 10.8 and the following requirements have been met:

- 1) The service wiring and equipment, including the meter socket enclosure, are installed, the service wiring terminated, and the service equipment covers installed.
- 2) The portions of the electrical system that are to be energized are complete and physically protected.
- 3) The grounding electrode system is complete.
- 4) The grounding and the grounded conductors are terminated in the service equipment.
- 5) At least one receptacle outlet with ground fault circuit interrupter protection for personnel is installed with the circuit wiring terminated.
- 6) The applicable requirements of the North Carolina Electrical Code apply.

10.8.3 Uses Prohibited

In no case shall any portion of the permanent wiring be energized until the portions have been inspected and approved by an electrical Code Enforcement Official. Failure to comply with this section may result in disconnection of power or revocation of permit.

10.8.4 Application for Temporary Power

Application for temporary power shall be made by and in the name of the applicant. The application shall explicitly state the portions of the energized electrical system, mechanical system, or plumbing system for which application is made, its intended use and duration.

10.8.5 Security and Notification

The applicant shall maintain the energized electrical system or that portion of the building containing the energized electrical system in a secured and locked manner or under constant supervision to exclude unauthorized personnel. The applicant shall alert personnel working in the vicinity of the energized electrical system to its presence.